Office of the District Fire Officer,
Karnataka Fire and Emergency Services Department
Davanagere Range,
Chitradurga Fire Station Premises,
Medehalli road, Chitradurga- 577 527.
Phone:08194-221900 **dfochitradurga.ksfes@ka.gov.in**

C.No: 69/School/CC/DFO/2024. **Date: 09-01-2025.**

To,

The Head Master
Shivu Academy,
Sakkara Road, Dharmapura village,
Hiriyur taluk,
Chitradurga Dist-577596.

Sir,

Sub:-Issue of **'Fire Safety Compliance Certificate'** with respect of fire prevention, fighting and evacuation measures maintained / required at ***" Shivu Academy ",*** situated ***at E-Swathu No.151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist-577596.***

Ref: C.No: 42/school/FSR/DFO/2024 dated: 09-01-2025.

With reference to the subject cited above, "Fire Safety Recommendation" was issued wide above reference to the premises of ***" Shivu Academy ",*** situated ***at E-Swathu No.151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist-577596.*** With a condition to fulfill the recommendations and compliance the same within 03 months.

The management of ***" Shivu Academy ",*** had requested for the compliance report from our department. In this regard the building was re-inspected by the District Fire officer, Chitradurga on ***09-01-2025*** and they have fulfilled all the Fire precautionary measures. and found all the precautionary measures are in good working condition at the time of inspection.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the "**Compliance Certificate**" to ***" Shivu Academy ",*** situated ***at E-Swathu No.151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist-577596.*** Subject to proper maintenance of fire fighting system in good working condition and at-least 40% of employees should be trained in basic fire fighting at our R.A Mundkur Fire & Emergency Academy, Bannerghatta road, Bengaluru.

This Compliance Certificate is valid till Dated 08-01-2026 and it is renewable.

Yours faithfully

09/01/25

District Fire Officer
Karnataka Fire And Emergency Services
Chitradurga Dist, Chitradurga-02

C.No: 42/School/FSR/DFO/2024

Office of District Fire officer,
Karnataka Fire & Emergency Services,
Medehalli Road, Chitradurga-577502
Date-09-01-2025.

To,

The Head Master
Shivu Academy,
Sakkara Road, Dharmapura village,
Hiriyur taluk,
Chitradurga Dist-577596.

Sir,

Sub: Issue of **'Fire Safety Recommendations'** ***to "Shivu Academy",*** situated ***at E-Swathu No.151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist.-577596.***

Ref: Applicants requisition letter dated:07-01-2025.

****

With reference to the subject above cited the premises **of** ***"Shivu Academy",*** situated at ***E-Swathu No. 151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist-577596.*** was inspected by the District Fire officer, Chitradurga on ***07-01-2025*** with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

Details of the Building/Premises.

01	Name and Address of the Applicant	The Head Master Shivu Academy, Sakkara Road, Dharmapura village, Hiriyur taluk, Chitradurga Dist-577596.
02	Name and Address of the Premises	E-Swathu No.151000300800320616 & 151000300800320617 Shivu Academy, Sakkara Road, Dharmapura village, Hiriyur taluk, Chitradurga Dist-577596.
03.	Name and Address of the Building Owner	The Head Master Shivu Academy, Sakkara Road, Dharmapura village, Hiriyur taluk, Chitradurga Dist-577596.

04.	Number of Building	One Building
05.	Number of Floors	Basement , Ground and 01 upper floor
06.	**Floor-wise details of Occupancy:-**	
	Basement	Store room-02
	Ground Floor	Class room-16, HM room-01
	1st floor	Class room-15, Staff room-01, Administrator room-01
07.	Height of the building	**07.80 mtrs**
08.	Site area	**7899-69 Sq. mtrs**
09.	**Built-up area of each floor:-**	
	Basement floor	212.92 Sq. mtrs
	Ground floor	1232.94 Sq. mtrs
	1st floor	1232.94 Sq. mtrs
10.	Total Built-up area	**2678.80 Sq. Mtrs**
11.	**Surrounding properties:-**	
	East(front)	Agricultural land
	West(rear)	Agricultural land
	North(side)	Agricultural land
	South(side)	Agricultural land
12.	**Open Space all around the building**	
	East(front)	04.00 mtrs
	West(rear)	06.00 mtrs
	North(side)	04.00 mtrs
	South(side)	07.00 mtrs
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

B. ***On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-***

S.No (01)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premises is abutting 06.50 mtrs wide road on Eastern side of the premises. The road is hardened to carry the weight of the weight of 45,000 Kg's.	Adequate

Office of The District Fire Officer, Sangareddy Dist.

02.	Number of Entrances	01 entrance of 04.00 mtrs wide.		--
03.	Diesel generator	Provided one diesel generator of 70 KV.		Complied.
04.	Number of Staircase	No of staircase	01	The staircase must be maintained free from obstruction.
		Width of the staircase	01.50mtr	
		Width of threads	0.28 mtr	
		Height of risers	0.13 mtr	
		No of risers per flight	12	
		Height of the hand drill.	--	
		Head roof clearance	3.30 mtr	
05.	Portable Extinguishers	Provided one water mist extinguisher of 09 ltrs capacity, one mechanical foam extinguisher of 09 ltrs capacity, one CO2 extinguisher of 4.5 kg capacity & 02 nos of ABC extinguisher of 06 kg capacity.		Complied
06.	Hose reel hose system	Hose reel hoses are provided at each floor near the staircase (one hose reel hose system for every 1000 sq.mtrs) The hose reel hose of min.19 mm size and of adequate length to reach the farthest point of every floor is provided, shut off branch having a nozzle of 05 mm size. It is connected at each landing of each building / block / wing/ tower.		Complied
07.	Terrace tank over respective tower terrace.	The system is connected to an over head tank of 5000 ltrs capacity each. **(The water tank should be kept exclusively for fire fighting purpose.)**		Complied

The District Fire Officer

08.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	The system is connected to two booster pumps of 450 LPM. (Further the system should be connected to an alternative source of power supply)	Complied
09	Escape routes	Direction in which the student have to move in the event of emergency should be displayed in the corridor on each floor during evacuation.	Complied.
10	Fire Order (Fire safety plans)	A notice board have been indicated the action to be taken by the employees in case of any emergency should be displayed with the telephone numbers of Hiriyur Fire Station i.e. 08193-263600 , 101 and the telephone no's nearest ambulance services and police station.	Complied.
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area , smoking here is an offence board have been written in the English & Kannada both languages have been prominently displayed at inside the entry/exit of the each floor.	Complied.
12	Fire Siren	A Fire Siren has been installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied
13	Nominate one fire Nodal officer.	Not Nominated	A fire nodal officer shall be nominated either from teaching or non teaching staff.
14	Fire Fighting Training	Not Imparted	At least 40% of the employee/staff should be got trained in basic fire fighting at

Office Of The District Fire Officer Chitradurga Dist-03

			R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore.
15.	***Fire precautionary measures :-*** A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to out side. G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing " **Fire Safety Recommendation** " to existing building of ***"Shivu Academy",*** situated at ***E-Swathu No.151000300800320616 & 151000300800320617, Sakkara road, Dharmapura village, Hiriyur taluk, Chitradurga dist-577596.*** is subjected to condition and compliance of the above recommendations in the column-4 of serial–B within 03 months and compliance to undersigned.

This **"Fire Safety Recommendation"** is valid for only one year from the date of issue.

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life Safety will have to be complied with mandatory.

Yours Faithfully

09/01/25

District Fire Officer
Karnataka Fire And Emergency Services
Chitradurga Dist, Chitradurga-08